



Product Service

C E R T I F I C A T E

No. B 098200 0031 Rev. 00

Holder of Certificate: **Caledonian Cables Limited**
 1/F., CMA Building, 64-66 Connaught Road Central,
 Central and Western District
 HONG KONG

Certification Mark:



Product: **Flame retardant cables**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64100180446101

Valid until: 2023-10-10

Boris Ouyang

Date, 2018-10-11 (Boris Ouyang)



Product Service

CERTIFICATE

No. B 098200 0031 Rev. 00

Model(s): FGD300 1VV-R (NYY), FGD400 1VV-R (NYY),
FGD300 1VVMV-R (NYRY), FGD400 1VVMV-R (NYRY)

Parameters:

Rated voltage	600/1000V
Conductors:	Annealed copper wire
Insulation:	PVC/A
Inner Covering: (For armoured types)	FGD300 1VVMV-R (NYRY), FGD400 1VVMV-R (NYRY): Extruded PVC or polymeric compound
Armour: (For armoured types)	FGD300 1VVMV-R (NYRY): Armoured with aluminium wire FGD400 1VVMV-R (NYRY): Armoured with galvanized steel wire
Sheath:	Extruded PVC Type ST1
Size	1C x 1.5mm ² to 800mm ² , 2C x 1.5mm ² to 5C x 400mm ² , 7C x 1.5mm ² to 48C x 2.5mm ²

Tested according to: IEC 60502-1:2004/A1:2009

Production Facility(ies): 096882