

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Medium voltage power cables

Name and address of the applicant

Caledonian Cables Limited  
1/F., CMA Building,  
64-66 Connaught Road Central  
Hong Kong

Name and address of the manufacturer

Caledonian (Shandong) Cables Limited  
No. 39, Chengbohu Road, Jibei Street, Jiyang District,  
Jinan City, Shandong  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Caledonian (Shandong) Cables Limited  
No. 39, Chengbohu Road, Jibei Street, Jiyang District,  
Jinan City, Shandong  
P.R. China

Ratings and principal characteristics

Rating Voltage U<sub>0</sub>/U(U<sub>m</sub>): 3,6/6 (7,2)kV  
6/10 (12)kV  
Max. conductor temperature: 90°C

Trademark / Brand (if any)

Caledonian Cables Limited

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

N2XS2Y	CU/XLPE/CS/PE	1X16...300mm <sup>2</sup>
N2XS2YR2Y	CU/XLPE/CS/PVC/AWA/PE	1X16...300mm <sup>2</sup>
N2XSE2Y	CU/XLPE/CS/PE	3X16...300mm <sup>2</sup>
N2XSEYR2Y	CU/XLPE/CS/PVC/SWA/PE	3X16...300mm <sup>2</sup>
N2XSYB2Y	CU/XLPE/CS/PVC/ATA/PE	1X16...300mm <sup>2</sup>
N2XSEYB2Y	CU/XLPE/CS/PVC/STA/PE	3X16...300mm <sup>2</sup>

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60502-2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24HRLR 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2024-04-14

Signature:

Kenny Shi