

Attestation of Conformity

No. N8A 17 06 98200 005

Holder of Certificate: Caledonian Cables Limited

1/F., CMA Building, 64-66 Connaught Road Central,

Central and Western District

HONG KONG

Product: Flame retardant cables

Single core non-sheathed LSZH cables

Model(s): FTX100 07Z-U (H07Z-U), FTX100 07Z-R (H07Z-R),

FTX100 07Z-K (H07Z-K)

Parameters: Voltage: 450/750V

Conductors: Plain or tinned copper wires to IEC 60228

class 1(-U), class 2(-R), class 5(-K)

Insulation: Thermosetting Cross-linked Polyolefin,

type EI5

Sizes:

FTX100 07Z-U (H07Z-U): 1C x 1.5mm² to 1C x 10mm²; FTX100 07Z-R (H07Z-R): 1C x 1.5mm² to 1C x 630mm²; FTX100 07Z-K (H07Z-K): 1C x 1.5mm² to 1C x 240mm²

Tested EN 50525-3-41:2011

according to:

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704101685905-00

Date, 2017-06-27

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1



